



Electric Utility Service Equipment Requirements Committee

Utility: Riverside Public Utility
 Contact Name: Tim Rezendes
 Phone Number: 951 351-6484

Place an X in the appropriate box for each drawing: A= Acceptable, C= Consult, U Unacceptable, N/A Not Applicable

Drwg	A	C	U	N/A	Explain all "Cs"
301	X				
301A			X		
301B	X				
302			X		Does not accept lockring
302A	X				
302B		X			Ringless unacceptable
303			X		Bolt-on meters not used by RPU
304	X				
305	X				
305A	X				
306	X				
307	X				
308	X				
308A	X				
309			X		Not used by RPU
311	X				
312	X				
313	X				
314	X				
315		X			Max. 350 cable allowed
316		X			No 3phase, 3wire
317		X			No 3phase, 3wire
318		X			Limited use
319		X			No 3phase, 3wire
320		X			No 3phase, 3wire
321		X			No 3phase, 3wire
322		X			No 3phase, 3wire
323			X		No 3phase, 3wire
324		X			No 3phase, 3wire
325	X				Meter socket on top panel
326	X				Meter socket on top panel
327		X			1200 amp Max
328A		X			No 3phase, 3wire
328B		X			No 3phase, 3wire
329A		X			No 3phase, 3wire
329B		X			No 3phase, 3wire
330	X				
331	X				
332	X				
333			X		
336				X	
337	Blank				
338				X	
339		X			
341	Blank				
342	X				

Drwg	A	C	U	N/A	Explain all "Cs"
343		X			Contact Engineering for wire size
343A		X			Contact Engineering for wire size
344		X			Limited use
345		X			1201 amps & up 60" min
346	Blank				
347	X				
348	X				
349		X			No 3phase, 3wire
350	Blank				
351		X			Term. Per Drwg 347
352	Blank				
353	X				
354	X				
401		X			Consult Engineering
402	Blank				
403	Blank				
404		X			Depends on field application
405	Blank				
406	Blank				
407				X	
408	X				
409				X	
410	Blank				
411		X			Consult on 3 wire
412	Blank				
413	Blank				
414				X	
415	Blank				
416				X	
417	Blank				
418		X			Depends on field application
419	Blank				
420				X	
501			X		Production meter required
502		X			Back feed breaker acceptable
503		X			No figure 1 wiring accepted
515			X		Net metering not available
516					Limited application
517					Limited application
518			X		No connection in utility cabinet
519			X		No connection in utility cabinet
G1	X				
G2	X				
G3	X				
G4	X				
G5		X			Limited application

RE	CHANGE	BY	DSGN	APPV	DATE	REV	CHANGE	BY	DSGN	APPV	DATE
A						D					
B						E					
C						F					

SHEET 2 OF 2	Indicates Latest Revision <input checked="" type="checkbox"/> Completely Revised New Page Information Removed EUSERC MANUAL SECTION 200	E-2
-------------------------	---	------------