



Electric Utility Service Equipment Requirements Committee

UTILITY: SEATTLE CITY LIGHT
CONTACT NAME: AIMEE KIMBALL
PHONE NUMBER: 206-549-2323

Place an X in the appropriate box for each drawing: A = Acceptable C = Consult U = Unacceptable N/A = Not Applicable

Drwg	A	C	U	N/A	Explain C's
301	X				
301A	X				
301B	X				
302			X		
302A		X			B
302B	X				
303				X	
304			X		
305	X				
305A		X			D
306		X			
307			X		
308		X			B
308A		X			B
309		X			B
310		X			
311		X			E
312		X			E
313			X		
314			X		
315			X		
316		X			F
317		X			A
318		X			F
319		X			A
320		X			F, <801A
321			X		
322		X			A
323			X		
324		X			A
325		X			C
326		X			C
327		X			C
328A		X			A
328B		X			A
329A		X			A
329B		X			A
330	X				
331	X				
332		X			MIN WIDTH 26"
333				X	
336		X			ONLY 1 SOCKET

Drwg	A	C	U	N/A	Explain C's
338		X			USE 332 LAYOUT
339		X			SCL CONST STD 1553.03
342	X				
343			X		
343A			X		
344		X			B
345	X				
347	X				
348		X			B
349		X			B
351		X			B
353		X			B
354		X			B
401		X			B
404		X			B
405				X	
406				X	
407		X			B
408	X				
409				X	
411				X	
414	X				
416				X	
418				X	
420		X			B
501		X			
502		X			
503		X			
515		X			
516		X			
517		X			
518		X			
519		X			
520		X			
G1	X				
G2		X			A
G3		X			
G4				X	
G5			X		
G6		X			
G7			X		
G8	X				

RE	CHANGE	BY	DSGN	APPV	DATE	REV	CHANGE	BY	DSGN	APPV	DATE
A	NO 3PHASE 3 WIRE					F	HINGED COVER REQUIRED				
B	PRE-APPROVAL REQUIRED					G					
C	DRAWING REQUIRED IN SWITCHGEAR					H					
D	NO TEST BLOCKS					I					
E	100A NOT ALLOWED					J					

SHEET 2 OF 2	Indicates Latest Revision <input checked="" type="checkbox"/>	Completely Revised	New Page	Information Removed	E-2
	EUSERC 2023 MANUAL				

SECTION 200