

Electric Utility Service Equipment			
Requirements Committee			
Utility:	Turlock Irrigation District		
Contact Name:	Sukhdeep S Gill		
Phone Number:	209-883-84132		

Place an X in the appropriate bx for each drawing A = Acceptable, C = Consult, U = Unacceptable, N

Dwg	A	C	U	N/A	Explain All "C's"
301	X				
301A	X				
301B					
302			X		
302A	X				
302B	X				
303	X				
304	X				
305	X				
305A	X				
306	X				
307		X			Meter Height 48", enclosed meters N/A
308	X				
308A					
309	X				
311	X				
312	X				
313	X				
314	X				
315		X			only With TID Approval
316	X				
317	X				
318	X				
319	X				
320	X				
321	X				
322	X				
323	X				
324	X				
325	X				
326	X				
327	X				
328A		X			No 3 Phasae 3 Wire
328B		X			No 3 Phasae 3 Wire

329A		X			No 3 Phasae 3 Wire
329B		X			No 3 Phasae 3 Wire
330	X				
331	X				
332	X				
333	X				
336			X		
337	Blank				
338			X		
339	X				
341	Blank				
342	X				

/A = Not acceptable

Dwg	A	C	U	N/A	Explain All "C's"
343	X				
343A		X			Requires Double Set Screws
344			X		
345	X				
346	Blank				
347	X				
348	X				
349			X		
350	Blank				
351		X			Factory Predrilled Buss Only
352	Blank				
353		X			36" minimum Height to Meter
354	X				
401	X				
402	Blank				
403	Blank				
404				X	
405	Blank				
406	Blank				
407	X				
408	X				
409	X				
410	Blank				
411	X				
412	Blank				
413	Blank				
414				X	
415	Blank				
416	X				
417	Blank				
418	X				
419	Blank				
420	X				
501					

502					
503					
515					
516					
517					
518					
519					
G1		X			Fig. 4 & 5 N/A
G2	X				
G3	X				
G4		X			No 3 phase 3 Wire
G5		X			Meter Height 48" min, 1 socket
G6		X			Only With TID Approval
G7		X			Fig. 2 not Acceptable
G8	X				